

10' high chain link fencing per physical security standard, chain link to be coated black.

North and west sides of fence to be as close as practical to easement line

Emergency evacuation gate with crash bar

24' wide double swing gate centered between reg buildings. Truck access only allowed, trucks with trailers will need to park along driveway.

All trees to be removed within fence boundary and 10' outside fence boundary as allowed by property lines. Fence to be minimum 5' west of reg buildings, minimum 10' north and south of reg buildings and 15' east of reg buildings. Entirety of fenced area to be covered by gravel

12' wide gravel drive to run east of fenced area and around NE corner of station and rejoin existing driveway (exact alignment and grading to be completed in field).

